PROPOSED 2020 NEC AMENDMENTS 5/3/22 MEETING

A. National Electric Code (NEC), <u>2020</u> Edition, and the standards referenced in that code for regulation of construction in this state.

Amend	Article 210.8 Ground-Fault	
2 tillelia	Circuit-Interrupter	
	Protection For Personnel	
Amend	Item (F) Outdoor Outlets	
Amend	Exception Exception	
Adopt	Item (2)	Ground-fault circuit-interrupter protection shall not be required on HVAC equipment.
<u>Adopt</u>	Item (G) Areas where	All 125-volt, 15- and 20-ampere receptacles, supplied by single-phase branch circuits rated 150 volts or less to
	welders are operated	ground, where welders are operated, for electrical hand tools or portable lighting equipment shall have ground-
		fault circuit interrupter protection for personnel.
Amend	Article 230.71 Maximum	
	Number of Disconnects	
Adopt	Exception	
Adopt	Item (1)	All pre-existing, renovations, alterations, repairs, or substantial improvement services shall not be required to
		have only one disconnecting means. The service disconnecting means for these listed construction types shall
		consist of not more than six switches or sets of circuit breakers, or a combination of not more than six switches
		and sets of circuit breakers, mounted in a single enclosure, in a group of enclosures, or in or on a switchboard or
		in a switchgear. There shall not be more than six sets of disconnects per service grouped in any one location.
		and a state great and a state of the state o
Amend	Article 551.71 Type	
	Receptacles Provided	
Amend	Item (F) GFCI Protection	Ground-fault circuit-interrupter protection shall be provided as required in 210.8(B). GFCI protection shall not be
		required for other than 125-volt, 15- and 20-ampere receptacles used in the recreational vehicle site equipment.
		Informational Note No. 1: Appliances used within the recreational vehicle can create leakage current levels at the
		supply receptacle(s) that could exceed the limits of a Class A GFCI device.
		Informational Note No. 2: The definition of Power-Supply Assembly in 551.2 and the definition of Feeder in
		Article 100 clarifies that the power supply cord to a recreational vehicle is considered a feeder.
		and the second s
Adopt	Article 630.8 Ground-Fault	All 125-volt, 15- and 20-ampere receptacles, supplied by single-phase branch circuits rated 150 volts or less to
	Circuit-Interrupter	ground, where welders are operated, for electrical hand tools or portable lighting equipment shall have ground-
	Protection for Personnel	fault circuit interrupter protection for personnel.
Amend	Article 702.2 Optional	The community process of personner
· mona	Standby Systems	
Adopt	Article 702.2(D) Permanent	When a permanently mounted residential generator is installed it shall meet the manufacturer's installation
	mounted residential	instructions. Carbon Monoxide alarms shall be added and installed as per the International Residential Code
	generators	Section R 315 amendment found in the Louisiana State Uniform Construction Code.
	<u> </u>	
L		

AUTHORITY NOTE: Promulgated in accordance with R.S. 40:1730.22(C) and (D) and 40:1730.26(1).

HISTORICAL NOTE: Promulgated by the Department of Public Safety and Corrections, State Uniform Construction Code Council, LR 33:291 (February 2007), amended LR 34:93 (January 2008), LR 34:883 (May 2008), LR 34:2205 (October 2008), LR 35:1904 (September 2009), LR 36:2574 (November 2010), effective January 1, 2011, LR 37:601 (February 2011), LR 37:913 (March 2011), repromulgated LR 37:2187 (July 2011), repromulgated LR 37:2726 (September 2011), LR 37:3065 (October 2011), LR 38:1994 (August 2012), amended by the Department of Public Safety and Corrections, Uniform Construction Code Council, LR 39:1825 (July 2013), LR 39:2512 (September 2013), LR 40:2609 (December 2014), amended by the Department of Public Safety and Corrections, Office of State Fire Marshall, LR 41:2387 (November 2015), amended by the Department of Public Safety and Corrections, Office of the State Fire Marshall, Uniform Construction Code Council, LR 44:95 (January 2018), repromulgated LR 45:932 (July 2019).